



2014000788Z



(2014) 国认监认字 (148) 号



检测  
CNAS L0484

防 爆 电 气 设 备

# 防 爆 合 格 证

郭斌

国家起重冶金及防爆电机质量监督检验中心

中国·佳木斯



# 防爆合格证

CERTIFICATE OF CONFORMITY

No. CJEx15.0532

制造单位 Manufacturer	无锡东元电机有限公司 (江苏省无锡市新区长江南路9号)
样品名称 Name of Product	隔爆型三相异步电动机
型号规格 Type of Product	TEBY-180L-6P 15kW 380/660V
防爆标志 Marking	Ex d IIB T4 Gb
产品标准 Product Standard	Q/320217ACV08-2015
总装图号 Drawing No.	32000A486

经对上述产品图样及技术文件的审查和样品检验, 确认符合下列标准:  
After examination of product drawings and technical documents and testing of sample, the product is in accordance the following standards:

GB3836.1-2010 《爆炸性环境 第1部分:设备 通用要求》

GB3836.2-2010 《爆炸性环境 第2部分:由隔爆外壳“d”保护的的设备》

说明事项 1、代表: TEBY-180M-2P、4P; TEBY-180L-4P、6P、8P  
Explanation 220V、230V、240V、380V、220/380V、400V、230/400V、415V、440V、460V、480V、525V、660V、380/660V、690V、400/690V、1140V、660/1140V Ex d IIB T4 Gb  
2、使用屈服强度 $\geq 640$ MPa的紧固件。

本证有效期至 2020年10月29日  
Valid Date

批准  
Approved by



国家起重冶金及防爆电机质量监督检验中心  
National Quality Supervision & Testing Centre of Crane and Metallurgical & Explosion-Proof Electric Machine

2015年10月30日

注: 本证仅对符合送检样品的产品有效, 证书持有者有责任保证产品符合标准规定。  
Notes: This certificate is only valid for the product that conforms to the sample submitted for test. This certificate holder has the responsibility to ensure that the product conforms to the standard.

地址: 中国黑龙江省佳木斯市安庆街3号  
Address: 3 Anqing Street, Jiamusi City, Heilongjiang Province, China  
<http://www.jexm.com.cn>  
E-mail: jczx@jexm.com.cn

Post code: 154005  
Fax: (0454) 8311260  
Tel: (0454) 8326353